



TOWNSHIP OF PLAINSBORO

Code Enforcement
Division of Fire Safety
641 Plainsboro Road
Plainsboro, NJ 08536
(609) 799-0909 ext. 2545

VERIFICATION AND TESTING OF EMERGENCY LIGHTING

Business Name: _____

Address: _____

**Emergency lighting was tested for one hour in accordance with
N.J.A.C. 5:70-3, 604.3.1.1 on the following date:**

604.3.1.1 Testing. Required emergency lighting systems including exit signs shall be tested for proper operation for a minimum of 30 seconds every month. An annual test shall be conducted for at least 1 hour. Equipment shall function properly for the duration of this test.

Test was witnessed and or performed by: _____

Authorized signature: _____